

Fire Detection Equipment Certificate of Inspection

Service Address

Shackleford Village Hall
Shackleford Road
Shackleford
Godalming, Surrey
GU8 6AE

Invoice Address

Shackleford Village Hall
C/O Richard Thompson
Norney Wood, Elstead Road
Shackleford, Godalming, Surrey
GU8 6AY

This is to certify that the Fire Alarm System at the above service address was serviced on 21 December 2018 by Matthew Sykes against SO18-063792.

We hereby certify that, apart from non-conforming components as recorded below, all of the equipment has been serviced in accordance with BS 5839-1:2017.

Qty	Description	Tested	Failed	Repaired	Replaced	New Installed
12	Detector	12	0	0	1	0
7	Call Point	7	0	0	0	0
5	Sounder	5	0	0	0	0
1	Fire Control Panel	1	0	0	0	0

Corrective Action

Completed 6 monthly fire alarm service to BS5839.

100% of devices tested.

Replaced 1 x optical smoke as over 10 years old.

All other devices have been updated.

System tested, bells sounded and all returned to normal.

I hereby certify that the technician has explained the works carried out and that I am duly authorised to approve these works. I understand that it is the duty of the responsible person, under fire legislation, to provide sufficient fire detection at all times.

churchesfire

COMPLETE FIRE CARE



Churches Fire Security Ltd Head Office Mayflower Close Chandlers Ford SO53 4AR

Tel: 0870 608 4350

Fax: 0870 608 4351

customer.services@churchesfire.com

www.churchesfire.com

Fire Detection Equipment Certificate of Inspection

Service Address

Shackleford Village Hall
Shackleford Road
Shackleford
Godalming, Surrey
GU8 6AE

Invoice Address

Shackleford Village Hall
C/O Richard Thompson
Norney Wood, Elstead Road
Shackleford, Godalming, Surrey
GU8 6AY

Name: Hazeu

Signature: 

churchesfire

COMPLETE FIRE CARE



Churches Fire Security Ltd Head Office Mayflower Close Chandlers Ford SO53 4AR

Tel: 0870 608 4350

Fax: 0870 608 4351

customer.services@churchesfire.com

www.churchesfire.com